



# **Vibration Monitoring Unit Series HE200**









C ∈ IECEE [H[ IECEX [H[Ex



Proc. Cont. Eq. Proc. Cont. Eq. for Haz. Loc.





- Vibration speed (mm/s, rms) Vibration acceleration (g, rms)
- ATEX / IECEx / EACEx Zone 2 / 22 and 1 / 21
- cULus OrdLoc / HazLoc Div 2
- 2 potential-free switching contacts
- Analogue current output: 4-20 mA
- Frequency range: 10 Hz 1000 Hz 1 Hz – 1000 Hz





Date of manufacture:	
Type description:	
Serial no.:	

Doc ID: M001-HE200 Stand: 2021-08-25

# **Operating instructions**

# Vibration Monitoring Unit Type HE200

Standard and ATEX / IECEx / EACEx

Version: 2021-08-25

#### Attention!

Prior to commissioning the product, the instruction manual must be read and understood.

All rights reserved, including rights to translation. Subject to modifications.

Please contact the company with any questions: HAUBER-Elektronik GmbH Fabrikstraße 6 D-72622 Nürtingen Germany

Tel.: +49 (0) 7022 / 21750-0 Fax: +49 (0) 7022 / 21750-50 info@hauber-elektronik.de www.hauber-elektronik.de

# 1 Contents

1	Contents	3
2	Safety information	4
3	Scope of this instruction manual	5
4	Vibration Monitoring Unit Type HE200	5
5	Intended Use	5
6	Scope of supply	5
7	Documents and Certificates	
8	Transfer of liability when operating in potentially explosive atmospheres	
9	Overview of application areas	
10	Example labels	
11	Information on the cULus validity range	
12	Functional safety instructions	
12.1	•	
	2 General notes	
	Instructions for the Fail Safe State	
13	Technical data	11
13.1		
13.2	Plectrical data	11
13.3	3 Operating range of the vibration monitoring unit	12
13.4	Typical frequency response	13
13.5	Mechanical data	14
13.6	6 Housing dimensions	14
14	Connections	16
15	Functional description	17
15.1	Operating conditions	17
15.2	2 Alarm and limit setting	17
15.3	B Limit values and delay times	18
16	Assembly and disassembly	20
16.1	General notes	20
16.2	Prixing the vibration monitoring unit to the mounting surface	20
16.3	3 Tamper protection	21
17	Installation and commissioning	22
17.1	General notes	22
17.2	Parthing concept	22
18	Maintenance and repair	23
18.1	General notes	23
18.2	2 Troubleshooting Table	23
19	Transport, storage and disposal	23
20	Coding HE200	25
21	EU declaration of conformity	26

# 2 Safety information

#### 2.1 General

The safety instructions are intended to protect people and property from damage and hazards that could arise as the result of improper use, incorrect operation or other misuse or devices, especially in explosive areas. Therefore, please read the operating instructions carefully before working on the product or operating it. The operating instructions must be accessible to operating personnel at all times.

Please make sure that all documents are present and complete before commissioning or performing other work on the product. If the documents have not all been delivered in full or if further copies are necessary, they can also be obtained in other languages.

The product is built according to the latest state of the art. However, hazards to people, machinery and systems can still arise as the result of improper handling, unintended use or operation and maintenance by persons inadequately trained on the product.

All those who are involved in the installation, operation and maintenance of the product in the operator's plant must read and understand the operating instructions.

The product may only be assembled, disassembled, installed and repaired by instructed, sufficiently trained and authorised personnel.

#### 2.2 Symbols used



This symbol indicates an explosion hazard.



This symbol indicates a hazard from electrical current.



This symbol indicates safety-related information.



This symbol indicates information unrelated to safety.

#### 3 Scope of this instruction manual

This instruction manual for the HE200-type vibration monitoring unit applies to the following versions:

HE200.00. HE200.01 and HE200.02

The variants are functionally identical. The variants HE200.01 and HE200.02 have additional certifications and labels which permit use in potentially exclusive atmospheres. For further information, see chapter "Overview of application areas" on page 7.

# 4 Vibration Monitoring Unit Type HE200

The HE200 type vibration monitoring unit is used to measure and monitor absolute bearing vibrations in machines in line with DIN ISO 10816. It offers the following features:

- Two limit values and associated delay timings can be adjusted separately.
- The two potential-free switching contacts will signal any exceeding of the relevant defined limit values. This can be used to generate a pre-alarm and a main alarm.
- Measurement parameter: The effective value (rms) of the vibration velocity (mm/s), or the effective value (rms) of the vibration acceleration (g)
- Analogue current output: Interference-free DC signal from 4-20 mA, proportional to the measuring range of the monitoring unit.

#### 5 Intended Use

Type HE200 is used to protect machines and mechanical equipment against undue strong vibrations. It may only be used in accordance with the specifications listed in the data sheet. It is used exclusively for measuring mechanical vibrations. **Main fields of application:** Fans, ventilators, blowers, electric motors, pumps, centrifuges, separators, generators, turbines and similar oscillating mechanical equipment.



If the equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.

#### 6 Scope of supply

All versions include:

- Vibration monitoring
- Cylinder head screw with hex socket, M8 x 20 mm
- Seal label
- Operating instructions

#### 7 Documents and Certificates

You can find the following documents and certificates for HE200 type at <a href="https://www.hauber-elektronik.de">www.hauber-elektronik.de</a> where they can be viewed and downloaded:

- EU type examination certificate ATEX, no.: UL 20 ATEX 2421 X Rev. 0
- Type examination certificate ATEX, no.: UL 21 ATEX 2570 X
- IECEx Certificate of conformity, no.: IECEx ULD 20.0022X
- UL Certificate of compliance, no.: E507077-20210204
- EACEx certificate, No.: %PLACEHOLDER%
- EAC Declaration
- Functional safety certificate (SIL 2)
- Safety manual SIL2

# 8 Transfer of liability when operating in potentially explosive atmospheres

The owner of the system is exclusively liable for the appropriate configuration of the electrical connections with respect to explosion protection regulations and correct commissioning.

If the system is installed by a sub-contractor on behalf of the owner, the system may only be commissioned after the sub-contractor has issued written confirmation in the form of a certificate of installation that the system has been installed correctly and professionally in accordance with the applicable legal regulations.

The operator is obliged to notify the responsible authorities of the initial commissioning of explosion-protected systems or system components and their re-commissioning following extensive changes or maintenance.

# 9 Overview of application areas

	Version	ci view of application		1	2	3	4	5	6
	Coding			HE200.00.xx.xx.xx.00.xxx	HE200.00.xx.xx.xx.01.xxx	HE200.02.xx.xx.xx.00.xxx	HE200.02.xx.xx.xx.01.xxx	HE200.01.xx.xx.xx.00.xxx	HE200.01.xx.xx.xx.02.xxx
	Connec	tion	M12 connector	х		х			
	00111100		Integrated cable		х		х	х	Х
		ing head temperature $T_M$ t temperature $T_A$	-40 °C ≤ T <sub>M</sub> ≤ 85 °C -40 °C ≤ T <sub>A</sub> ≤ 60 °C	х		х		х	
		on for application area	-35 °C ≤ T <sub>M</sub> ≤ 125 °C -35 °C ≤ T <sub>A</sub> ≤ 60 °C		x		x		
		≤ T <sub>M</sub> ≤ 80 °C ≤ T <sub>A</sub> ≤ 60 °C	-20 °C ≤ T <sub>M</sub> ≤ 125 °C -20 °C ≤ T <sub>A</sub> ≤ 60 °C						x
	CE	IEC [fi[		х	х	х	х	х	х
	C UL US	Proc. Cont. Eq. Ord. Loc E507077					х		
	<b>€x</b>	II 3G Ex ec IIC T4 Gc II 3D Ex tc IIIC 135°C Do	UL 21 ATEX 2570 X			х	х		
22	IECEx	Ex ec IIC T4 Gc Ex tc IIIC 135°C Dc	IECEx ULD 20.0022 Issue 0X			х	х		
2 and	C UL US			x	x				
x Zone	EHLEx	?	?			х	х		
ш	Segurança  U  BR  OCP 00220	Ex ec IIC T4 Gc Ex tc IIIC 135°C Dc	UL-BR 21.1250X			х	х		
	CCC	Ex nA IIC T4 Gc Ex tD A22 IP66/67 T135	°C No: 2021122315114599			х	х		
	⟨Ex⟩	II 2G Ex db IIC T4 Gb II 2D Ex tb IIIC 135°C Db	UL 20 ATEX 2421 X					х	x
and 21	IECEx	Ex db IIC T4 Gb Ex tb IIIC 135°C Db	IECEx ULD 20.0022 Issue 0X					x	x
Zone 1 a	ER[Ex	?	?					х	x
Ex Zo	Segurança  INMETRO OCE ODES	Ex db IIC T4 Gb Ex tb IIIC 135°C Db	UL-BR 21.1250X					х	x
	ccc	Ex d IIC T4 Gb Ex tD A21 IP66/67 T135	°C No: 2021122315114599					x	x

#### 10 **Example labels**

Variant 1 - HE200.00.xx.xx.xx.00.000





Manufacturer: (производитель) Hauber-Elektronik GmbH Fabrikstraße 6 72622 Nürtingen Germany (Германия) www.hauber-elektronik.de

#### Variant 2 - HE200.00.xx.xx.xx.01.xxx





Manufacturer Hauber-Elektronik GmbH 72622 Nürtingen Germany (Германия) www.hauber-elektronik.de

#### Variant 3 - HE200.02.xx.xx.xx.00.000







Manufacturer: Hauber-Elektronik GmbH Fabrikstraße 6 72622 Nürtingen Germany (Германия) www.hauber-elektronik.de

Variant 4 - HE200.02.xx.xx.xx.01.xxx







Manufacturer: Hauber-Elektronik GmbH Fabrikstraße 6 72622 Nürtingen Germany (Герм www.hauber-elektronik.de

Variant 5 - HE200.01.xx.xx.xx.00.xxx









Manufacturer: Hauber-Elektronik GmbH Fabrikstraße 6 72622 Nürtingen Germany (Германия) www.hauber-elektronik.de

Variant 6 - HE200.01.xx.xx.xx.02.xxx







IP 66/67 Type 4x Enclosure





Manufacturer: (производитель) Hauber-Elektronik GmbH Fabrikstraße 6 72622 Nürtingen Germany (Германия) www.hauber-elektronik.de

# 11 Information on the cULus validity range

In order to install the device according to the UL/CSA/IEC standard, the following information must be observed.

#### **Electrical protection**



Devices must be protected by means of fuses, circuit breakers, overheating protection, impedance-limiting switches or similar to ensure protection against excessive power output if there is a fault in the device. Protection must be applied to supply lines and switching lines.



A circuit breaker suitable for 30V/3A according to UL Standard 489/CSA Standard (C22.2) no. 5/IEC 60947-2 must be installed near the device.



A fuse suitable according to UL Standard 248/CSA Standard (C22.2) no. 248/IEC 60127 must be installed near the device. The fuse must have a slow triggering characteristic ("T").

#### Limited temperature range

The following temperature ranges apply for variants with integrated cable:

Measuring head temperature	-30 °C ≤ T <sub>M</sub> ≤ +80° C
Ambient temperature	-30 °C ≤ T <sub>Amb</sub> ≤ +60° C

# 12 Functional safety instructions

# 12.1 Safety level / key indicators

The HE200 vibration monitoring hardware was tested by TÜV Süd. The results meet the criteria according to SIL2 and Pl-d.

MTTF	984898h = 112,43 years
DC <sub>avg</sub>	>90% Diagnostic Coverage
MTTF <sub>d</sub>	2889526h = 329,85 years = <b>LOW</b>
CCF	100 (fulfilled)

Further safety metrics and information can be found in the safety manual.

#### 12.2 General notes



A reboot of the vibration monitoring unit must be performed annually in order to test the switching of potential-free switching contacts.

#### 12.3 Instructions for the Fail Safe State

When the power supply is switched on, the vibration monitoring unit will perform a self-test. During operation, self-tests are performed automatically in cycles. If a self-test fails, the vibration monitoring unit switches to the Fail Safe State.

In the Fail Safe State all status LEDs are lit, all potential-free switching contacts are open and the analogue current output supplies 0 mA.

# 13 Technical data

# 13.1 General data



Each sensor has one of the listed measuring and frequency ranges. Further ranges on request.

Please indicate the measuring and frequency range in your request.

Measuring range:	0 - 8 mm/s rms (only for frequency range > 10 Hz) 0 - 10 mm/s rms 0 - 16 mm/s rms 0 - 20 mm/s rms 0 - 25 mm/s rms 0 - 32 mm/s rms 0 - 50 mm/s rms 0 - 64 mm/s rms 0 - 128 mm/s rms 0 - 1 g rms 0 - 2 g rms 0 - 4 g rms 0 - 8 g rms 0 - 10 g rms
Measuring accuracy:	± 10% (as per DIN ISO 2954)
Transverse sensitivity:	< 5%
Frequency range:	10 Hz–1,000 Hz (standard) 1 Hz–1000 Hz
Calibration point:	159.2 Hz and 90% amplitude of measuring range
Ready delay:	10 sec seconds
Maximum acceleration:	±16.5 g
Lifetime:	10 years

Tab. 1: General data

### 13.2 Electrical data

Output signal:	1 x 4-20 mA (proportional to the measuring range)
Switching contact:	2 x potential-free switching contacts (pre- and main alarm)
Switching contact switching load:	1A / 30 V DC
Power supply:	24 V DC ± 10%
Power input (max.):	100 mA
Load/output load (max.):	500 Ω
Automatic:	As soon as the vibration values fall below the limit values, the potential-free switching contacts <b>automatically</b> re-energize.

Tab. 2: Electrical data

#### 13.3 Operating range of the vibration monitoring unit

The operating range is independent from the measuring range. It can be derived from the maximum acceleration, which is 16.5 g across all frequencies. The maximum measurable vibration velocity is based on the formula

$$v_{max} = \int a_{max}$$

For sinusoidal vibration,  $v_{max} = \frac{a_{max}}{2\pi f}$  applies

Fig. 1: shows the operating range of the vibration monitoring unit, which is limited by the maximum measurable vibration velocity in mm/s depending on the frequency in Hz.




Fig. 1: Operating range diagram

- 1 Frequency in Hz
- 2 Vibration velocity in mm/s
- 3 Operating range of the vibration monitoring unit

#### Reading example:

Frequency (Hz)	Maximum measurable Vibration velocity (mm/s)
250	103
400	64
1000	25

Tab. 3: Reading example of operating range

# 13.4 Typical frequency response

# 10 Hz-1,000 Hz (standard)

The frequency response is recorded using a reference sensor.

• 4 Hz. . . 1200 Hz acceleration sensor




Fig. 2: Typical frequency response 10 Hz–1000 Hz

- 1 Frequency in Hz
- 2 Amplification in dB

#### 1 Hz-1000 Hz

The frequency response is recorded using two reference sensors.

- 1 Hz. . . 10 Hz laser sensor
- 10 Hz. . . 1200 Hz acceleration sensor




Fig. 3: Typical frequency response 1 Hz-1000 Hz

- 1 Frequency in Hz
- 2 Amplification in dB

#### 13.5 Mechanical data



For more information see Section "Coding" on page 25.

Housing motorial:	Stainless staal V2A metarial no : 1 4205 (standard)
Housing material:	Stainless steel V2A, material no.: 1.4305 (standard)
Fastening:	Cylinder head Allen screw M8 x 20 mm Thread pitch: 1.25 mm (standard)
Mounting:	Housing must be earthed via the M8 fastening
Cover tightening torque:	5 Nm
Measuring direction:	Along the fastening axis
Weight:	approx. 500 g
Protection class:	Cover and plug connection closed: IP 66/67 Type 4X Enclosure Product is suitable for outdoor applications
Max. humidity:	100%

Tab. 4: Mechanical data

# 13.6 Housing dimensions





Fig. 4: Housing with M12 connector

- 1 M12 connector
- 2 Measuring direction

Fig. 5: Housing with integrated cable

- 1 Cable gland
- 2 Connecting cable
- 3 Measuring direction



All measurements in mm

Fig. 6: Housing with integrated cable and clamp sleeve base for protective metal hose

- 1 Cable gland
- 2 Connecting cable
- 3 Measuring direction
- 4 Clamp sleeve base for protective metal hose

#### 14 Connections




Fig. 7: Wiring diagram

- 1 Potential-free switching contact 1 (Pin 5: +, Pin 6: -)
- 2 Potential-free switching contact 2 (Pin 7: +, Pin 8: -)
- 3 Evaluation unit



The wiring diagram shows the alarm status or the current status! Potential-free switching contacts 1 and 2 are open.

### 15 Functional description



In an explosive atmosphere the vibration monitoring unit HE200 will only be opened in a de-energized state.

The HE200 type has two limit values Lim1 and LIM2 and the corresponding delay times, which can be adjusted separately. If the defined limit value is exceeded and after the set delay time has expired, the corresponding potential-free switching contact is opened. This can be used to generate a pre-alarm and a main alarm.

A subsequent fall below the limit value is also signalled at potential-free switching contacts 1 and 2, i.e. the respective switching contact automatically closes.

The HE200 type also has an analogue current output. This supplies direct current of 4-20 mA proportional to the vibration amplitude.

## 15.1 Operating conditions

Operating state	Reading	Switching contacts	LED status
ОК	≤ Limit value	Closed	green
WARNING	> Limit value, delay time runs	Closed	green + yellow
ALARM	> Limit value, delay time expired	Open	red
Fail Safe State	0 mA	Open	red + yellow + green
De-energized	0 mA	Open	All LEDs off

Tab. 5: Operating conditions

#### 15.2 Alarm and limit setting

By pressing the "Save Config" button, the current configuration is displayed by the LEDs around the HEX switches. For further information, see chapter "Limit values and delay times" on page 18.

The limit values and delay times are calibrated using the respective HEX switch. As soon as a switch position is changed, the LEDs around the Hex switch start to blink. The number of blinking LEDs represents the current position of the HEX switch. To save the configuration, press and hold down the "Save Config" button for three seconds. Acceptance of the configuration is signalled by steady lighting up of the LEDs in the selected HEX switch position.

After about five minutes the LEDs turn off automatically.

# 15.3 Limit values and delay times

The **SET rotary button** has 16 positions, representing the limit value of an alarm. The measuring range of the vibration monitoring unit is divided into 16 linear steps.

In general:  $limit\ value = \frac{upper\ limit\ measruing\ range}{16} \times SET\ position$ 

**Example:** Limit setting

Measuring range: 0-32 mm/s

SET rotary button Pos.: 8 (9)

Limit value: 16 mm/s (18 mm/s)

SET- Position ▼	Limit values (mm/s)									
Measuring- range →	0 – 8 mm/s	0 – 10 mm/s	0 – 16 mm/s	0 – 20 mm/s	0 – 25 mm/s	0 – 32 mm/s	0 – 50 mm/s	0 – 64 mm/s	0 – 128 mm/s	
0	0,0	0	0	0	0	0	0,00	0	0	
1	0,5	0,625	1	1,25	1,563	2	3,13	4	8	
2	1,0	1,25	2	2,5	3,125	4	6,25	8	16	
3	1,5	1,875	3	3,75	4,688	6	9,38	12	24	
4	2,0	2,5	4	5	6,25	8	12,50	16	32	
5	2,5	3,125	5	6,25	7,813	10	15,63	20	40	
6	3,0	3,75	6	7,5	9,375	12	18,75	24	48	
7	3,5	4,375	7	8,75	10,938	14	21,88	28	56	
8	4,0	5	8	10	12,5	16	25,00	32	64	
9	4,5	5,625	9	11,25	14,063	18	28,13	36	72	
10	5,0	6,25	10	12,5	15,625	20	31,25	40	80	
11	5,5	6,875	11	13,75	17,188	22	34,38	44	88	
12	6,0	7,5	12	15	18,75	24	37,50	48	96	
13	6,5	8,125	13	16,25	20,313	26	40,63	52	104	
14	7,0	8,75	14	17,5	21,875	28	43,75	56	112	
15	7,5	9,375	15	18,75	23,438	30	46,88	60	120	

Tab. 6: Limit values vibration velocity

SET- Position ▼	Limit values (g)									
Measuring- range →	01 g	02 g	04 g	06 g	08 g	010 g				
0	0	0	0	0	0	0				
1	0,063	0,125	0,25	0,375	0,5	0,625				
2	0,125	0,25	0,5	0,75	1	1,25				
3	0,188	0,375	0,75	1,125	1,5	1,875				
4	0,25	0,5	1	1,5	2	2,5				
5	0,313	0,625	1,25	1,875	2,5	3,125				
6	0,375	0,75	1,5	2,25	3	3,75				
7	0,438	0,875	1,75	2,625	3,5	4,375				
8	0,5	1	2	3	4	5				
9	0,563	1,125	2,25	3,375	4,5	5,625				
10	0,625	1,25	2,5	3,75	5	6,25				
11	0,688	1,375	2,75	4,125	5,5	6,875				
12	0,75	1,5	3	4,5	6	7,5				
13	0,813	1,625	3,25	4,875	6,5	8,125				
14	0,875	1,75	3,5	5,25	7	8,75				
15	0,938	1,875	3,75	5,625	7,5	9,375				

Tab. 7: Limit values vibration acceleration

# **Delay times**

TIME Position	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Delay time (secs)	0	1	2	3	4	5	7.5	10	12.5	15	17.5	20	25	30	45	60

Tab. 8: Delay times

# 16 Assembly and disassembly

#### 16.1 General notes

Assembly and disassembly work on and with the monitoring unit may only be performed by an authorised specialist familiar with the safety regulations governing handling electrical components! When using EX-certified monitoring units in potentially explosive atmospheres, the professional must also be familiar with the relevant safety regulations!



Before assembly and disassembly disconnect the monitoring unit from the power supply! Separate plug connections must always be de-energized! If EXcertified monitoring is operated in a potentially explosive atmosphere, there is otherwise an explosion hazard, due to spark formation!



The monitoring unit housing must be earthed via the fastening - through the machine earth of the mounting surface or through a separate protective conductor (PE)!

#### 16.2 Fixing the vibration monitoring unit to the mounting surface

#### **Prerequisites**


- Mounting surface is clean and even; i.e. free of paint, rust, etc.
- Threaded hole in mounting surface:
   15 mm, M8

#### **Tools and material**


- Hex socket key SW 6, SW 8
- Torque wrench SW 6, SW 8
- Cylinder head screw with hex socket M8x20
- Spring washers for M8

#### Work steps and instructions

- Unscrew housing cover from housing base;
  - Allen key 8 mm
- Attach monitoring unit using cylinder head screws and spring washers with 8 Nm on mounting surface;
   Allen key 6 mm
- Screw the housing cover back onto the housing base and tighten to 5 Nm;
   Allen key 8 mm



Fastening on mounting surface (1)



Tighten housing cover with torque wrench (2)



In order to avoid cold welding of the housing cover to the housing base, the thread is treated ex-works with an assembly paste for stainless steel connections.

# 16.3 Tamper protection

#### Attach seal labels

The "SEALED" seal label reveals any unauthorised opening of the housing cover.

After installation of the housing cover by the system operator, the seal label shall be attached to the side above the housing joint.

If any tampering is attempted, the seal label is destroyed and the tampering will be visible to the system operator




Fig. 8: Seal label

# 17 Installation and commissioning

#### 17.1 General notes

Installation and commissioning of the vibration monitoring unit may only be performed by an authorised specialist familiar with the safety regulations governing handling electrical components. When installing and commissioning EX-certified monitoring units in potentially explosive atmospheres, the professional must also be familiar with the relevant safety regulations!



The commissioning will only be carried out with the housing cover correctly screwed on (tightening torque = 5 Nm)! If EX-certified monitoring is operated in a potentially explosive atmosphere, there is otherwise an explosion hazard, due to spark formation!



Protect the connection cable and any extension cable from electrical interference and mechanical damage! Local regulations and instructions must be observed in doing so!

#### 17.2 Earthing concept

The earthing concept intends that the shielding of the cable is electrically connected to the housing of the sensor via the knurled nut and is at earth potential at the evaluation unit or at the control cabinet. In case of long cable lengths, it is recommended to disconnect the shield at the evaluation unit (4) to avoid compensating currents via the shield.



Fig. 9: Earthing concept HE200

- 1 Machine earth
- 2 Evaluation unit (measuring device, PLC, etc.)
- 3 Cable shielding
- 4 Earth potential evaluation unit
- 5 Optional protective metal hose (Only available for variants with an integrated cable)

# 18 Maintenance and repair

#### 18.1 General notes



Repair and cleaning work on vibration monitoring units may only be performed by an authorised specialist familiar with the safety regulations governing handling electrical components.



Before repair and cleaning disconnect the monitoring unit from the power supply! Separate plug connections must always be de-energized!



Immediately replace defective connection cables!

A defective vibration monitoring unit must be completely replaced!



The vibration monitoring unit HE200 is maintenance-free!

# 18.2 Troubleshooting Table

Fault	Cause	Action			
No measured value (4-20 mA)	No power supply	Check power source and/or supply			
	Discontinuity in connecting cable	Replace connecting cable			
	Fuse defective	Replace fuse			
	Connection has incorrect polarity	Connection of correct pole			
	Vibration monitoring unit faulty	Replace Vibration Monitoring Unit			
Switching contact doesn't switch	Wrong limit value set	Set correct limit value			
	No power supply	Check power source and/or supply			
	Discontinuity in connection	Replace connecting cable			
	Fuse defective	Replace fuse			
	Connection has incorrect polarity	Connection of correct pole			
	Defective monitoring unit	Replace monitoring unit			
Incorrect Reading	Vibration monitoring unit not mounted in a friction-locked manner	Mount vibration monitoring unit in a friction-locked manner			
	Vibration monitoring unit installed in wrong place	Install vibration monitoring unit in correct place			
	EMC problems	See "Earthing concept" on page 22.			

Tab. 9: Troubleshooting Table


# 19 Transport, storage and disposal


The sensor must be protected from damaging environmental factors and mechanical damage during transport with the use of adequate packing.

The sensor may not be stored in ambient temperatures outside the permitted operating temperature.

The product contains electronic components and must be disposed of properly in accordance with local laws and regulations.

# 20 Coding HE200





050 = 5 m integrated cable

100 = 10 m integrated cable



Is your desired configuration not listed? Please contact us and we can offer you a solution for your specific needs.

# 21 EU declaration of conformity

#### **Declaration of conformity**

HAUBER-Elektronik GmbH Fabrikstraße 6 D-72622 Nürtingen

declares under its sole responsibility that the products listed below, to which this declaration refers, comply with the essential health and safety requirements of the directives and standards listed below.

#### **Product series**

HE200, HE205, HE250, HE255

#### **ATEX Annex**

UL International Demko A/S certifies as **Notified Body No. 0539** under the European Community Council Directive of February 26<sup>th</sup> 2014 (2014/34/EU) that the manufacturer maintains a production quality system that complies with **Annex IV** of this Directive.

#### **Directives and standards**

<b>EU-Directive</b>	Standard
2014/30/EU	EN 61000-6-7:2015
	EN 61000-6-3:2007 + A1:2011
	EN55011:2016 + A1:2017
2014/34/EU	IEC 60079-0:2017 + Corr.1:2020 + I-SH01:2019 + I-SH02:2019
	IEC 60079-1:2014 + Corr. 1:2018 + I-SH01:2020
	IEC 60079-7:2017
	IEC 60079-31:2013

# Affixed CE-Marking

**C**€<sub>0539</sub>

#### Marking and certificates

HE200.02 / HE205.02 / HE250.02 / HE255.02

Marking	Certificate
<ul><li>☑II 3G Ex ec IIC T4 Gc</li><li>☑II 3D Ex tc IIIC 135°C Dc</li></ul>	UL 21 ATEX 2570 X

#### HE200.01 / HE205.01 / HE250.01 / HE255.01

Marking	Certificate
<ul><li>☑II 2G Ex db IIC T4 Gb</li><li>☑II 2D Ex tb IIIC 135°C Db</li></ul>	UL 20 ATEX 2421 X Rev. 0

#### Unterschrift

Nürtingen, den 03.05.2021

Place and date

Tobias Bronkal, managing proprietor

K. Kronkal